



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 16 02 80934 003

Initial No. CLS2 13 04 80934 001

Certificate Holder: Yitac (S) Pte Ltd
2 Woodlands Sector 1
#03-04 Woodlands Spectrum
Singapore 738068
SINGAPORE

Product: Thermal Insulation Materials

Brand Name: PIRALU

Model(s): PIRALU

Product Details: Bulk Density: 51kg/m³
Tested on the embossed aluminium foil face
(Rating: Class 0)

Standard(s): BS 476-6:1989/A1:2009
BS 476-7:1997

Country of Origin: Spain

Test Report(s): 7191055964-MEC13/1-OKH, 7191055964-MEC13/2-YWA

Issued on: 2016-03-02

Valid until: 2019-04-22

Vice-President (Certification Department)
TÜV SÜD PSB

Page 1 of 1

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.sg



Cert No: PD-2002-01